

Santon Holland bv
Attn. Mr. H. de Sterke
P.O. Box 59024
3008 PA ROTTERDAM

Your ref. Mr. H. de Sterke
Our ref. 2130545.00-QUA/INC
10-1152 vGe/Sco
Author M.T.H. van Gemen
Tel. +31 26 356 2007
Fax +31 26 352 5800
E-mail lv-components@kema.com


Arnhem, August 17, 2010

Subject: Declaration - X type switches - Santon Holland bv, Rotterdam, the Netherlands.

Dear Mr. De Sterke,

With regard to the knobs of your above mentioned products, KEMA Quality B.V. declares herewith the following:

Type Knob: B type, standard
R type, with pad-locking
O type, with padlocking



KEMA Quality
a DEKRA company

- The types R and O knob's have been mechanically tested in combination with switch X75.50B4-R-XS. The switch knobs were tested for 10.000 cycli, comprising the follow cycli:
" OFF position-push actuator/rotation to "ON" position, push /rotation to "OFF " position and etc.
- Furthermore, the knobs R and O type comply with the IEC 60529 requirements for classification IP65, when built-in in a enclosure of IP65 or greater.

We hope this information will suffice. Should you have any further questions please do not hesitate to contact us.

Yours sincerely,

KEMA Quality B.V.

A handwritten signature in blue ink, appearing to be 'M.T.H. van Gemen', written over a horizontal line.

M.T.H. van Gemen