Suitable as photovoltaic disconnect switch in accordance with Article 690 of NFPA 70 (NEC) UL 508, including the requirements for PV application CSA C22.2 No. 0, - CSA C22.2 No. 14




P


Terminals Scheme								
			Rear Side		On Positions			
				Right				
			2		v	~		
5			2		X	X		
4		-/-		2	X	X		
3	r	-/-	1		X	X		
2		-/-		1	X	x		
1		empty						
	Contacts are	made in "X	" mari	ked posi	ition.			


Symbols for interconnection: [

	Symbols for interconnection: [
nominal voltage (DC poles)	U	600	Vo		
nominal current (DC poles)	T T	16	Ac		
method of mounting	DIN rail and or Base mounting [B]				
number of poles, DC single pole switching					
utilization category DC	Photovoltaic disconnect switch				
actuator	ordered without a knob				
method of operation	independent manual operation				
positions	OFF at 3 hr, ON at 6 hr, OFF at 9 hr, ON at 12 hr				
rated impulse withstand voltage	Uimp	8	kV		
insulation voltage	UI	600	٧		
rated thermal current uninterrupted duty	lu	16	A		
rated short-time withstand current (1s)	lcw	750	A		

ated conditional short-circuit current			5	kA
nax power dissipation			1	W
ninimum required dimensions of enclosures L x W x H*		124	124 x 47 x 84,5	
see the drawing for the height of the switch.	The number of layers N is:		5	
ightening torque terminal screws M4, min	max,	1,5	1,7	Nm
		13	15	Lb,In
tightening torque M3 screw in the standard black knob, min max.		0,5	0,7	Nm
		5	6	Lb.Ir
ightening torque for the nut on the single hole	e mounting knob, min max.	1,8	2,0	Nm
		16	18	Lb.Ir
wire size, "Use 75°C Copper Wire Only", minimum required fine wire cross-section: 2,5		2,5	mm.	
			12	AWG
ambient temperature allowed between		- 20	- 20 to + 70 °C	
storage temperature allowed between		- 40	to + 80 °C	·c
naximum relative humidity, without condensa	tion at 20°C		90	%
ominal voltage (AC poles)	U			Vac
ominal current (AC poles)	1			A ac
umber of AC poles				
uxiliary contact:	No auxiliary contact			
veight			254	g
ccessories:				







Mounting instructions


In the application all ratings have to be respected. The switch is designed for Use on a Flat Surfface of a Type 1 Enclosure or equivelent. The minimum dimensiones of the enclosure must be respected according to the applicable standards. The position of the handle of the switch shall be marked with a Position Indication plate or direct on thesurface of the enclosure to guide proper indication. The "On" and "Off" position may be marked using the symbols "I" and "O" according IEC 417 Symbols 5007 and 5008. The terminals, without interconnection can take copper wires up to 6 mm². The recommended Spade Tongue Terminals may have a maximum width of 9 mm. For CSA and UL applications, registered Spade Tongue Terminals must be used. The registration numbers are UL: E13288 and CSA: LR7189 (for instance type 165015 from Tyco). After mounting, the wiring must be checked and the switch must operate smoothly.

Maintenance

The X type switches are designed for a very long life but it is advised to do some simple yearly maintenance.

- Check the installation for signs of overload or overheating. The terminals may not exceed the limit of 85°C under full load.

- By operating the switch a few times (5x) the contacts will clean themselves and the switch will have a longer life.



Dimensions, specifications and data shown could be subject to change without notice.

Superior Switch Solution