



JFGA.E347771 Fuses for Photovoltaic Systems

[Page Bottom](#)

Fuses for Photovoltaic Systems

[See General Information for Fuses for Photovoltaic Systems](#)

ETI ELEKTROELEMENT D D

E347771

OBREZIJA 5

1411 IZLAKE, SLOVENIA

Cat. No.	Interrupting Capacity			Rating		
	Volts		Amps	Volts		Amps
	DC	AC		DC	AC	
10x38gPV	1,000	—	10,000	1,000	—	6-16
10x85gPV	1,500	—	10,000	1,500	—	10-16
10x85gPV	1,200	—	10,000	1,200	—	20

[Last Updated](#) on 2013-02-28

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".