

CERTIFICATE

KEMA No.: 2124402.01



Issued to:
Applicant:

Santon Holland bv
Hekendorpstraat 69
3079 DX, ROTTERDAM, The Netherlands

Manufacturer/Licensee:

Santon Holland bv
Hekendorpstraat 69
3079 DX, ROTTERDAM, The Netherlands

Product(s) : switch-disconnector
Trade name(s) : SANTON
Type(s)/model(s) : X75.32

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-3:2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 901095

KEMA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 24 September 2009 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

drs. G.J. Zoetbrood
Managing Director

F.S. Strikwerda
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	switch-disconnector
trade name(s)	:	SANTON
type(s)	:	X75.32
rated insulation voltage (Ui)	:	1000 V ac
conventional free air thermal current (Ith)	:	32 A
conventional enclosed thermal current (Ithe)	:	32 A
ratings/utilization category (Ue-Ie)	:	<u>DC-21A</u> 750 V 32 A
rated short-time withstand current (Icw)	:	700 A - 1 s
rated short-circuit making capacity (Icm)	:	1400 A
rated conditional short-circuit current (Icc)	:	5000 A when protected with fuse-links limiting the cut-off current to a maximum of 1,282 kA and the Joule intergral to 2734,1 A ² s Fuse-links during test: manufacturer Siba, type NH00, 80 A gBG, 1000 V, 20 kA
rated impulse withstand voltage (Uimp)	:	8 kV
operational performance without current	:	category A
with current	:	8500 operating cycles
connection capacity	:	1500 operating cycles
method of operation	:	2,5 mm ² - 6 mm ² flexible
number of position of contacts	:	independent operation, rotary,
number of poles	:	4 positions (0°, 90°, 180°, 360°)
rating/utilization category of auxiliary circuits	:	8 with 1 single pole switch contact, maximum 9 layers
number of poles	:	<u>AC-15</u> 250 V 16 A
degree of protection	:	combination of maximum 4 single pole contacts (NO or NC)
	:	IP20 or IP65 when mounted in an enclosure with gland of the shaft for panel mounting

Additional information

Remarks:

Composition of the contacts during the tests:
2 contacts in serie in the + pole and 1 contact in the - pole.

The service condition of the switch-disconnector are:

-5 °C to +70 °C, for utilization category DC-21A

-25 °C to +70 °C for utilization category DC-21B

For checking the service condition -25 °C to +70 °C additional tests partly based on Annex Q of IEC 60947-1, category B are carried out.

TESTS

Test requirements
EN 60947-3:2009

Test result
The test results are laid down in KEMA test file 2124402.01.

Conclusion
The examination proved that all test requirements were met.

Tested by : M.T. H. van Gemen

Checked by : H.L. Schendstok

Two handwritten signatures in blue ink. The first signature is above the name M.T. H. van Gemen, and the second is a larger, more stylized signature above the name H.L. Schendstok.

Factory locations
Santon Holland bv,
Hekendorpstraat 69, 3079 DX, ROTTERDAM, The Netherlands