



CB TEST CERTIFICATE

Ref. Certificate No.

NL_29259

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	rotary switch-disconnector		
Applicant:	Santon International B.V.	Hekendorpstraat 69 3079 DX Rotterdam	The Netherlands
Manufacturer:	Santon International B.V.	Hekendorpstraat 69 3079 DX Rotterdam	The Netherlands
Factory:	Santon International B.V.	Berkenwoudestraat 4-6 3079 JA Rotterdam	The Netherlands
Rating and principal characteristics:	Rotary switch-disconnector with 4 positons 90°, both directions. Uimp 8 kV, Ui 1000 V, Icw 700 A-1s, Icm 1400 A, maximum 12 poles, DC-21B, rating 32 A - 650 Vdc, 25 A - 800 Vdc, 20 A - 850 Vdc, 16 A - 1000 Vdc		
Trade mark (if any):	SANTON		
Model/Type reference:	XA65.32....., XA80.25, XA85.20, XA100.16		
Additional information:			
Sample of product tested to be in conformity with IEC:	60947-3(ed.2);am1		
Test Report Ref. No:	2167173.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: H.R.M. Barends

Date of issue: 2013-12-09

