

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50526332

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
Z.D.Y

Unser Zeichen *Our Reference*  
01-SDW-CN21EZFY 002

Ausstellungsdatum *Date of Issue*  
02.12.2021  
(day/mo/yr)

Genehmigungsinhaber *License Holder*  
JD Auspice Co., Ltd.  
3F., No. 288, Sec. 2  
Zhonghua Rd., Xinzhuang Dist.,  
New Taipei City 242  
Taiwan

Fertigungsstätte *Manufacturing Plant*  
040-0002313994

## Prüfzeichen *Test Mark*



Type Approved  
Safety  
Regular Production  
Surveillance

www.tuv.com  
ID 1111247788

Geprüft nach *Tested acc. to*  
EN 60947-1:2007+A1+A2  
EN 60947-3:2009+A1+A2

## Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

## Lizenzentgelte - Einheit *License Fee - Unit*

### Fuse Holder (Fuse Holder)

Type Designation	: FH-01 FH-01L	5
Utilization Category	: DC-PV0	
Number of Pole	: 1-pole	
Rated Operational Voltage Ue	: DC 1000V	
Rated Operational Current Ie	: 32A	
Rated Insulation Voltage Ui	: 1000V	
Rated Impulse Withstand Voltage Uimp	: 6kV	
Conventional Free Air Thermal Current Ith	: same as Ie	
Conditional Short-circuit Current	: 33kA	
Pollution Degree	: 3	

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com  
Fax: +49 221 806-3935

Zertifizierungsstelle



Kenny Shi