



## CB TEST CERTIFICATE

Ref. Certificate No.

NL-16780

### IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Rotary switch disconnecter for solar application		
Applicant:	Santon International B.V.	Hekendorpstraat 69 3079 DX ROTTERDAM	The Netherlands
Manufacturer:	Santon International B.V.	Hekendorpstraat 69 3079 DX ROTTERDAM	The Netherlands
Factory:	Santon International B.V.	Hekendorpstraat 69 3079 DX ROTTERDAM	The Netherlands
Rating and principal characteristics:	Rotary switch disconnecter with 4 positions 90°, both directions, DC-21A, In 32 A, Ue 750 V, Ui 1000 V, Icw 700 A, Icm 1400 A, Icc 5 kA, Uimp 8 kV, maximum 9 layers.		
Trade mark (if any):	SANTON		
Model/Type reference:	X75.32...		
Additional information:			
Sample of product tested to be in conformity with IEC:	60947-3(ed.3)		
Test Report Ref. No:	2124402.50		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.  
Utrechtseweg 310  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands



Signed by: F.S. Strikwerda

Date of issue: 2009-09-23