THE NEW SANTON X-TYPE SWITCH

TECHNICAL SPECIFICATIONS AND INSTRUCTIONS FOR USE

SANTON X-TYPE SWITCH: X75.25B2E-A


Switch disconnector for solar application according to IEC 60947-1&3




	Contact scheme			Positions			
	Marking	Symbol	Marking	1	2	3	4
11		-/-					
10		-/-					
9		-/-					
8		-/-					
7		-/-					
6		-/-					
5		-/-					
4		-/-					
3		-/-					
2	-1	-/-	-1		Χ		
1	+1	-/-	+1		Χ		


Contacts are made in "X" marked position. Symbols for interconnection: []

Technical data	Symbol		Unit					
nominal voltage (DC poles)	Ue	750	V dc					
nominal current (DC poles)	le	25	A dc					
nominal voltage (secund rating DC poles, if requested)	Ue		V dc					
nominal current (secund rating DC poles, if requested)	le		A dc					
method of mounting	DIN rail and or Base	e mounting [B]						
number of DC poles		2						
utilization category DC		21						
actuator	standard black [A]							
positions	OFF at 12 hr, ON at							
rated impulse withstand voltage	Uimp	8	kV					
insulation voltage	Ui	1000	V					
rated thermal current uninterrupted duty	lu	25	Α					
rated short-time withstand current (1s)	lcw	750	Α					
rated short-circuit making capacity	Icm	1,4	kA					
rated conditional short-circuit current		5	kA					
max. cut-off current			kA					
max power dissipation		2,0	W					
method of operation	independent manual operation							
minimum required dimensions of enclosures I x w x h*		124x47x56	mm					
* see the drawing for the hight of the switch. The number of	layers H is:	6						
terminal screws M4 need a tightening torque, min max.		1,5 1,7	Nm					
tightening torque screw in the standard black knob, min ma	ax.	2,0 2,5	Nm					
minimum required fine wire cross-section: IEC60947-1, table	9	4	mm²					
ambient temperature allowed between		- 5 and + 40	°C					
storage temperature allowed between		- 20 and + 70	°C					
maximum relative humidity, without condensation		90	%					
pollution degree		2						
IP rating terminals		IP20						
IP rating gland of the shaft in case of single hole panel mounting								
nominal voltage (AC poles)	Ue	0	V AC					
nominal current (AC poles)	le	0	A AC					
number of DC poles 0								
uxiliary contact, nominal current 16A at 250 V, AC15 No auxiliary contact								
weight 157			g					
accessoires:								





H is the number of layers in the switch



Mounting instructions

In the application all ratings have to be respected. When building the switch in an enclosure, the space envelope must be respected. The terminals can take flexible wires up to 6 mm² and fork shoes for wires up to 10 mm² (type 3547C from Vogt). After mounting, the wiring must be checked and the switch must operate smoothly.

Maintenance

The X type switches are designed for a very long life but it is advised to do some simple yearly maintenance.

- Check the installation for signes of overload or overheating. The terminals may not exceed the limit of 85°C under full load.
- By operating the switch a few times (5x) the contacts will clean themselves and the switch will have a longer life.

Dimensions, specifications and data shown could be subject to change without notice.