

Certificate of Compliance

Certificate: 2206053

Master Contract: 237829

Project: 2206053

Date Issued: January 15, 2010

Issued to: Santon Holland BV
Willingestraat 2
3087 AN, Rotterdam
THE NETHERLANDS

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: S. Christov

Authorized by: M.H.J. Hoendervangers
Area Director Europe



PRODUCTS

3211 07 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

3211 87 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus- Certified to US Standards

Manual switch, rotary open type, for front panel, rear panel and din-rail mounting,
Cat. No. X60.32..., rated, 32 A 600 Vdc, resistive, single pole, auxiliary contacts rated A300

Notes:

1. Cat. No. X32 is certified as open component type and the acceptability of the final combination is to be determined by the CSA International or another NRTL.
2. On manufacturers request the switches were tested for short circuit withstand of 5.000 rms Symmetrical Amperes, at 600 Volts dc max. when protected by class H fuses 40A max
3. On manufacturers request Cat. No. X60.32... was tested at ambient temperature of -25°C and +70°C

Certificate: 2206053

Project: 2206053



Master Contract: 237829

Date Issued: January 14, 2010

APPLICABLE REQUIREMENTS

CSA C22.2 No. 0	- General Requirements
CSA C22.2 No. 14	- Industrial Control Equipment
UL508	- Industrial Control Equipment



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 2206053

Master Contract: 237829

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
2206053	January 15, 2010	Original Certification of Industrial control manual switch, Cat. No. X60.2.. CSA C22.2 No 14-05, UL 508 17 th ed.