



CB TEST CERTIFICATE

Ref. Certificate No.

NL-16888

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Switch-disconnector for solar application		
Applicant:	Santon International B.V.	Hekendorpstraat 69 3079 DX ROTTERDAM	The Netherlands
Manufacturer:	Santon International B.V.	Hekendorpstraat 69 3079 DX ROTTERDAM	The Netherlands
Factory:	Santon International B.V.	Hekendorpstraat 69 3079 DX ROTTERDAM	The Netherlands
Rating and principal characteristics:	DC-21B, In 32 A, Ue 1000 V, Ui 1000 V, Icw 700 A-1s, Icm 1400 A, Icc 5kA, SCPD(fuse-link NH00, 35 A gB, type 308, 1000 V, 20 kA) Uimp 8 kV, maximum 12 layers. For further information see Annex.		
Trade mark (if any):	SANTON		
Model/Type reference:	Series X100.32...		
Additional information:			
Sample of product tested to be in conformity with IEC:	60947-3(ed.3)		
Test Report Ref. No:	2124402.52		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: F.S. Strikwerda

Date of issue: 2009-09-28

Ratings and principal characteristics:

Rotary switch disconnecter with 4 positions 90°, both directions, DC-21B, In 32 A, Ue 1000 V, Ui 1000 V, Icw 700 A-1s, Icm 1400 A, Icc 5kA, SCPD (fuse-link NH00, 35 A gB, type 308, 1000 V, 20 kA) Uimp 8 kV, maximum 12 layers, contact composition during the tests 2 contacts in series in the + pole and 1 contact in the – pole.

Auxilliary contact, AC-15, In16 A, Ue 250 Vac 1-pole.

General:

- IP20 or IP65 when build-in an enclosure with gland of the shaft for panel mounting
For ambient temperature :-5 °C to 40 °C
- method of mounting front: single hole mounting, bottom: screw mounting and or top-hat rail mounting