

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - REPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1100518

Product: Fuse-disconnectors

Type: OPF10-1, OFP10-2

Rating: Ue 1000 V DC, Ie 32 A, Ui 1000 V

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: B a K production s.r.o.
Purkratice 18, 397 01 Písek, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 002665-01/01 of: 14.07.2010

A sample of the product was found to be in conformity with:
ČSN EN 60647-1 ed.4:08 cl. 8.2.1.1, 8.2.3, 8.2.4;
ČSN EN 60647-3 ed.2:00+A1:02+A2:06+Z1:2010 cl.8.3.3- 8.3.7

The validity of the certificate is limited to: 31.7.2013

22.7.2010

Prague

Miroslav Sedláček
Certification and Inspection Manager



Stamp



002665-01