



中国国家强制性产品认证证书

证书编号: 2011010302512264

委托人名称、地址

Santon International B.V.
Hekendorpstraat 69, 3079 DX, ROTTERDAM, The Netherlands

生产者(制造商)名称、地址

Santon International B.V.
Hekendorpstraat 69, 3079 DX, ROTTERDAM, The Netherlands

生产企业名称、地址

Santon Holland B.V.
BERKENWOUDestraat 4-6, 3079 JA, ROTTERDAM, The Netherlands

产品名称和系列、规格、型号

隔离开关

X60.25(型号解释见附件); Ui:1000V; Ith:25A; Ue:DC600V; Icw:700A/1s;
Icm:1400A; Iq:5000A; 使用类别: DC-21A/DC-21B; IP:20; 配用的辅助触头:AC-
15:Ue/Ie:AC250V/16A;

产品标准和技术要求

GB 14048.3-2008


上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2011年11月24日

有效期至: 2016年11月24日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2011010302512264

NAME AND ADDRESS OF THE APPLICANT

Santon International B.V.
Hekendorpstraat 69, 3079 DX, ROTTERDAM, The Netherlands

NAME AND ADDRESS OF THE MANUFACTURER

Santon International B.V.
Hekendorpstraat 69, 3079 DX, ROTTERDAM, The Netherlands

NAME AND ADDRESS OF THE FACTORY

Santon Holland B.V.
BERKENWOUDestraat 4-6, 3079 JA, ROTTERDAM, The Netherlands

NAME, MODEL AND SPECIFICATION

Switch disconnecter

X60.25 series; Ui:1000V; Ith:25A; Ue:DC600V; Icw:700A/1s; Icm:1400A;
Iq:5000A; DC-21A/DC-21B; IP:20; Auxilary Contacts:AC-15;Ue/Ie:AC250V/16A;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Nov.24, 2011 Date of expiry: Nov.24, 2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



中国国家强制性产品认证证书

附录:

第 1 页 共 3 页

证书编号: 2011010302512264

纸号: 215091

型号的解释(Explanation of model/ type):

X 60 . 25 D — 8 C — — A
I II III IV V VI VII VIII IX X XI

I X type

II DC nominal voltage divided by ten
60 = DC600V

III Nominal current
25 = 25A

IV Mounting type

D = double mounting, Bottom and panel mounting, applicable for knob: A, D, O

B = bottom mounting and DIN rail mounting, applicable for knob A, D, R

P = panel mounting, applicable for knob A, D, O

R = reverse panel mounting, (= panel mounting) applicable for knob A, D, O

V Long gland panel mounting

L = with long gland panel mounting

Blank = without long gland panel mounting

VI layers

1 = 1 layer, 1 pole; 2 = 2 layer, 2 poles; 3 = 3 layer, 3 poles; 4 = 4 layer, 4 poles

5 = 5 layer, 5 poles; 6 = 6 layer, 6 poles; 7 = 7 layer, 7 poles; 8 = 8 layer, 8 poles

9 = 9 layer, 9 poles; 10 = 10 layer, 10 poles; 11 = 11 layer, 11 poles; 12 = 12 layer, 12 poles

VII auxiliary contact

C = INO

O = INC

S = INC+INO

Blank = without auxiliary contactor

VIII number of auxiliary contactors, when more than one provided

2 = 2 auxiliary contactor; 3 = 3 auxiliary contactor; 4 = 4 auxiliary contactor;

Blank = 1 auxiliary contact or without auxiliary contactor if VII is blank

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书


附录:

第 2 页 共 3 页

证书编号: 2011010302512264

纸号: 215091


IX switch positions and blockings




applicable for knob A and D;




applicable for A and D




applicable for knob A and D;



applicable for A and D




applicable for knob A;D and O;




applicable for knob A; D


and O;




applicable for knob A and D;




applicable for knob A and D



applicable for knob R;



applicable for knob A and D



applicable for knob A and D

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 3 页 共 3 页

证书编号: 2011010302512264

纸号: 215091

X = “-“

XI knob

- A = standard black knob
- B = pad lockable knob grey/grey
- C = pad lockable knob black/grey
- D = standard black, with thread through the shaft
- O = pad lockable knob, for single hole mounting
- P = motor driven switch without a knob
- Q = motor driven switch with black knob
- R = pad lockable knob in red
- S = special lockable knob in black

When the code for the knob is between brackets the switch is supplied without the knob but the shaft is suitable for that knob. For instance (C) means switch will be supplied without the knob and is suitable for knob type C.

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



