



# 中国国家强制性产品认证证书

证书编号: 2012010302552334

## 委托人名称、地址

Santon International B.V.  
Hekendorpstraat 69, 3079 DX, ROTTERDAM, The Netherlands

## 生产者(制造商)名称、地址

Santon International B.V.  
Hekendorpstraat 69, 3079 DX, ROTTERDAM, The Netherlands

## 生产企业名称、地址

Santon Holland B.V.  
BERKENWOUDestraat 4-6, 3079 JA, ROTTERDAM, The Netherlands

## 产品名称和系列、规格、型号

隔离开关

XA100.16: 额定绝缘电压(Ui): 1000V; 约定发热电流(Ith): 25A; 额定工作电压(Ue): DC1000V, DC850V, DC800V; 额定工作电流(Ie): 16A/DC1000V, 20A/DC850V, 25A/DC800V; 额定短时耐受电流(Icw): 500A 1s; 额定短路接通能力(Icm): 500A; 使用类别: DC-21B; 具体型号解释见附件

## 产品标准和技术要求

GB 14048.3-2008

上述产品符合强制性产品认证实施规则  
CNCA-01C-011:2007的要求, 特发此证。

发证日期: 2012年07月02日      有效期至: 2017年07月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

### 中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010302552334

## NAME AND ADDRESS OF THE APPLICANT

Santon International B.V.  
Hekendorpstraat 69, 3079 DX, ROTTERDAM, The Netherlands

## NAME AND ADDRESS OF THE MANUFACTURER

Santon International B.V.  
Hekendorpstraat 69, 3079 DX, ROTTERDAM, The Netherlands

## NAME AND ADDRESS OF THE FACTORY

Santon Holland B.V.  
BERKENWOUDestraat 4-6, 3079 JA, ROTTERDAM, The Netherlands

## NAME, MODEL AND SPECIFICATION

Switch disconnecter

XA100.16: Ui: 1000V; Ith: 25A; Ue: DC1000V, DC850V, DC800V; Ie:  
16A/DC1000V, 20A/DC850V, 25A/DC800V; Icw: 500A 1s; Icm: 500A; Utilization  
Category:DC-21B;

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Jul.02, 2012      Date of expiry: Jul.02, 2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



# 中国国家强制性产品认证证书

第 1 页 共 3 页  
纸号: 496138

附录:

证书编号: 2012010302552334

型号的解释:

XA100.16  $\frac{D}{I}$   $\frac{L}{II}$   $\frac{8}{III}$   $\frac{E}{IV}$   $\frac{-A}{V}$   $\frac{VI}{VI}$

I XA100.16 type

II Mounting type

D = double mounting, Bottom and panel mounting, applicable for knob: A, D, O  
B = bottom mounting and DIN rail mounting, applicable for knob A, D, R  
P = panel mounting, applicable for knob A, D, O  
R = reverse panel mounting, (= panel mounting) applicable for knob A, D, O

III long gland

L = with long gland panel mounting  
Blank = without long gland panel mounting

IV poles

1 = 1 poles, 1 layers ; 2 = 2 poles, 2 layers ; 3 = 3 poles, 3 layers; 4 = 4 poles, 4 layers;  
5 = 5 poles, 5 layers ; 6 = 6 poles, 6 layers; 7 = 7 poles, 7 layers ; 8 = 8 poles, 8 layers;  
9 = 9 poles; 9 layers ; 10 = 10 pole; 10 layers; 11 = 11 poles, 11 layers; 12 = 12 poles, 12 layers

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# 中国国家强制性产品认证证书

附录:

证书编号: 2012010302552334

第 2 页 共 3 页


纸号: 496138

V


## Switch positions and blockings

Standard ON-OFF


No code




Type U




Type E




Type F




Type G




Type H




Type L




Type M



Type N



Type T



VI knob

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# 中国国家强制性产品认证证书

附录:

证书编号: 2012010302552334

第 3 页 共 3 页

纸号: 496138

- A = standard black knob
- B = knob with padlocking grey/grey
- D = standard black knob with thread through the shaft
- O = knob with padlock possibility, for single hole mounting
- R = knob with padlock possibility and door interlock, for bottom or double mounting, in red colour
- S = knob with padlock possibility and door interlock, for Bottom or double mounting, in black colour

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



