

# CERTIFICATE

Issued to:  
Applicant:  
**Santon International B.V.**  
**Hekendorpstraat 69**  
**3079 DX Rotterdam, The Netherlands**

Manufacturer/Licensee:  
**Santon International B.V.**  
**Hekendorpstraat 69**  
**3079 DX Rotterdam, The Netherlands**

Product(s) : rotary switch-disconnector  
Trade name(s) : SANTON  
Type(s)/model(s) : XA65.32P12-A

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-3:2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 901095


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.


The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 11 June 2013 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2161965.01

DEKRA Certification B.V.

  
drs. G.J. Zoetbrood  
Managing Director

  
H.R.M. Barends  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY  
THE DUTCH COUNCIL  
FOR ACCREDITATION





**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product	:	rotary switch-disconnector
trade name	:	SANTON
type	:	XA65.32P12-A
rated insulation voltage (Ui)	:	1000 V dc
conventional free air thermal current (Ith)	:	32 A
ratings/utilization category (Ue-Ie)	:	<u>DC-21B</u> 650 Vdc 32 A
rated short-time withstand current (Icw)	:	700 A - 1 s
rated short-circuit making capacity (Icm)	:	1400 A
rated impulse withstand voltage (Uimp)	:	8 kV
operational performance	:	category B
without current	:	1700 operating cycles
with current	:	300 operating cycles
connection capacity	:	1,5 mm <sup>2</sup> - 6 mm <sup>2</sup> flexible
method of operation	:	semi-independent operation, rotary,
number of position of contacts	:	4 positions (0°, 90°, 180°, 360°)
number of polestype of contact	:	maximum 12 poles1 single pole contact per pol
contact composition	:	1 contact in each pole
degree of potection	:	IP20 or IP66 when mounted in an enclosure of $\geq$ IP 66 with gland of the shaft for panel mounting
For use in ambient temperatures	:	-40 °C to 70°C

**TESTS****Test requirements**

EN 60947-3:2009

**Test result**

The test results are laid down in DEKRA test file 2161965.50.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : M.T. H. van Gemen

Checked by : H.L. Schendstok

**Factory location**

Santon Holland B.V.

Berkenwoudestraat 4-6, 3079 JA, Rotterdam

The Netherlands