Switch disconnector for solar application according to IEC 60947-1&3 by Dekra (KEMA)






	2		Terminals			100	160	SARAS	
No.	Front Side		Symbol			On Positions			
	Left	Right	2000000	Left	Right	1	2	3	4
					-				H
						П			Ħ
	_								
7			_/_	+2		X			
6			_/_		+2	X			
5	-2		-/-	-2		X			
4		-1	_/_		-1	X			
3		1	_/_	+1		X			
2			_/_	311	+1	X			
1			empty						

	Contacts are made in "X" market Symbols for interconnection: [						
Technical data	Symbol Me	rit		Unit			
rated operational voltage (DC poles)	Ue		1000	V dc			
rated operational current (DC poles)	le		40	A dc			
rated operational voltage (second rating DC poles, if requested)	Ue		0	V dc			
rated operational current (second rating DC poles, if requested)	le		0	A dc			
rated operational voltage (third rating DC poles, if requested)	Ue		0	V dc			
rated operational current (third rating DC poles, if requested)	le		0	A dc			
method of mounting	nting [D]						
number of DC poles			4				
utilization category DC	DC-21B						
actuator	standard black [A	]					
positions	OFF at 12 hr, ON	at 3 hr [E]					
rated impulse withstand voltage	Uimp		8	kV			
insulation voltage	Ui		1000	V			
rated thermal current uninterrupted duty	lu		40	Α			
rated short-time withstand current (1s)	lcw		750	Α			
rated short-circuit making capacity	Icm		1,4	kA			
rated conditional short-circuit current			5	kA			
max power dissipation			3,6	W			
method of operation	independent man	ual operation					
minimum required dimensions of enclosures L x W x H*		12	4 x 47 x 105,5	mm			
* see the drawing for the height of the switch. The number of layers N is:			7				
Enclosure depth from inside bottom to outside top, required for the switch	and knob		138,5	mm			
knob operation force		max.	1,4	Nm			
tightening torque terminal screws M4 , min max.		1,5	1,7	Nm			
tightening torque panel mounting nut, min max.		2,0	2,5	Nm			
tightening torque M3 screw in the standard black knob, min max.		0,5	0,7	Nm			
minimum required fine wire cross-section: IEC60947-1, table 9			2X6	mm2			
ambient temperature allowed between			- 20 to + 70	.c			
storage temperature allowed between			- 40 to + 80	-c			
maximum relative humidity, without condensation at 20°C			90	%			
pollution degree			2				
IP rating terminals			IP20				
IP rating gland of the shaft in case of single hole panel mounting			IP65				
rated operational voltage (AC poles)	Ue			Vac			
rated operational current (AC poles)	le			A ac			
number of AC poles (for general use)							
minimum required fine wire cross-section: IEC60947-1, table 9				mm2			
auxiliary contact(s), AC15			No auxilia	ry contac			
auxiliary contact ratings			Week Committee C				
weight			315	g			
accessories:							


Superior Switch Solutions



## **Mounting instructions**

In the application all ratings have to be respected. When building the switch in an enclosure, the space envelope must be respected according to the applicable standards. The terminals, without interconnection can take copper wires up to 6 mm2. The recommended Spade Tongue Terminals may have a maximum width of 9 mm. For CSA and UL applications, registered Spade Tongue Terminals must be used. The registration numbers are UL: E13288 and CSA: LR7189 (for instance type 165015 from Tyco). After mounting, the wiring must be checked and the switch must operate smoothly.

- The X type switches are designed for a very long life but it is advised to do some simple yearly maintenance.
- Check the installation for signs of overload or overheating. The terminals may not exceed the limit of 85°C under full load.
- By operating the switch a few times (5x) the contacts will clean themselves and the switch will have a longer life.



Dimensions, specifications and data shown could be subject to change without notice.

Superior Switch Solutions