

JD Auspice Co., Ltd.
Xu Yijie
-
3F., No. 288, Sec. 2 Zhonghua Rd.,
Xinzhuang Dist., New Taipei City
242
Taiwan

Date : 14.08.2015
Our ref. : WCJ ZC10
Your ref.: X.Y.J.

Ref : R TÜV-Mark Approval

Type of Equipment : Fuse-disconnector
Model Designation : See Certificate
Certificate No. : R 50316326 0001
Report No. : 14712315 002

Dear Xu Yijie,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body


James Li

CC: ZHEJIANG MINGRONG ELECTRICAL

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50316326

Blatt *Page*
0001

Ihr Zeichen *Client Reference*
X.Y.J.

Unser Zeichen *Our Reference*
ZC10-WCJ- 14712315 002

Ausstellungsdatum
14.08.2015

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

Fertigungsstätte *Manufacturing Plant*

JD Auspice Co., Ltd.
3F., No. 288, Sec. 2 Zhonghua Rd.,
Xinzhuang Dist., New Taipei City
242
Taiwan

ZC10-WCJ-14712315 001

Prüfzeichen *Test Mark*

Geprüft nach *Tested acc. to*
EN 60947-3:2009+A1



Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Switch (Fuse-disconnector)

Type Designation	:	FH-01	FH-01L	6
		(JDA)		
Number of Pole	:	1 Pole		
Utilization Category	:	DC-20B		
Rated Operational Voltage Ue	:	DC 1000V		
Rated Operational Current Ie	:	30A		
Rated Insulation Voltage Ui	:	DC 1000V		
Conventional Free Air Thermal Current Ith	:	30A		
Rated Conditional Short-circuit Current	:	10kA		
Pollution Degree	:	2		
Degree of Protection	:	IP20		
Suitability for Isolation	:	Yes		

The labelling requirements acc. to EU Directive 2001/95 have to be observed for distribution within the EEA.


6

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg
Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle



James Li

ZHEJIANG MINGRONG ELECTRICAL
PROTECTION CO., LTD.
Saipin Chen

Date : 14.08.2015
Our ref. : WCJ ZC10
Your ref.: X.Y.J.

-
Wei 11th Road
Economic Developing Zone
Yueqing, Zhejiang 325600
P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : Fuse-disconnector
Model Designation : See Certificate
Certificate No. : R 50316326 0001
Report No. : 14712315 002

Dear Saipin Chen,

Enclosed please find above certification documents.
Please forward these originals to the certificate holder.

If you contact our office, please quote our reference above.

We thank you for your cooperation.

The certificate holder is: JD Auspice Co., Ltd.

With kind regards,

Certification Body


James Li

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询