

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50316326

Blatt *Page*  
0001

Ihr Zeichen *Client Reference*  
X.Y.J.

Unser Zeichen *Our Reference*  
ZC10-WCJ- 14712315 002

Ausstellungsdatum  
14.08.2015

*Date of Issue*  
(day/mo/yr)

**Genehmigungsinhaber *License Holder***  
JD Auspice Co., Ltd.  
3F., No. 288, Sec. 2 Zhonghua Rd.,  
Xinzhuang Dist., New Taipei City  
242  
Taiwan

**Fertigungsstätte *Manufacturing Plant***  
ZC10-WCJ-14712315 001

## Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*  
EN 60947-3:2009+A1

**Zertifiziertes Produkt (Geräteidentifikation)**  
*Certified Product (Product Identification)*

**Lizenzentgelte - Einheit**  
*License Fee - Unit*

Switch (Fuse-disconnector)

Type Designation	: FH-01	FH-01L	6
	(JDA)		
Number of Pole	: 1 Pole		
Utilization Category	: DC-20B		
Rated Operational Voltage Ue	: DC 1000V		
Rated Operational Current Ie	: 30A		
Rated Insulation Voltage Ui	: DC 1000V		
Conventional Free Air Thermal Current Ith	: 30A		
Rated Conditional Short-circuit Current	: 10kA		
Pollution Degree	: 2		
Degree of Protection	: IP20		
Suitability for Isolation	: Yes		

The labelling requirements acc. to EU Directive 2001/95 have to be observed for distribution within the EEA.

6

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**  
Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com  
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle



James Li