



A P P R O V A L S ®

## Certificate of Conformity

**Certificate No.:** SAA-191411-EA

**Certificate Holder:** Santon International B.V.  
Hekendorpstraat 69,  
3079 DX Rotterdam,  
The Netherlands

**Class Description:** DC Isolator  
**Product Description:** PV Switch-Disconnecter  
**Brand Name:** santon  
**Model No.:** XBE+  
**Markings:** DC-PV2  
Ue = 1100V, Ie = 5A, ambient -5°C to +70°C  
Ue = 1000V, Ie = 8A, ambient -5°C to +70°C  
Ue = 800V, Ie = 12.5A, ambient -5°C to +70°C  
Ue = 500V, Ie = 25A, ambient -5°C to +70°C  
Ui = 1100V Uimp = 8kV  
Icw = 700A 1s, Icm = 4xIe, Ithe = 50A  
IP66NW (enclosed outdoor),  
IP20 (enclosed indoor)

**Standard:** AS 60947.3:2018  
AS/NZS IEC 60947.1:2015

**Conditions:** Nil

**Approval Mark:** RCM and SAA-191411-EA

**Date First Registered:** 27 June 2019

**Date of Expiry:** 27 June 2024

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



Issued: 27-06-19 191411/1

[www.jas-anz.org/register](http://www.jas-anz.org/register)