THE NEW SANTON X-TYPE SWITCH

SANTON X-TYPE SWITCH:

X60.16B4E-A



Switch disconnector for solar application according to IEC 60947-1&3



	Contact scheme			Positions				
-	Marking	Symbol	Marking					
12		-/-						
11		-/-						
10		-/-						
9		-/-						
8		-/-						
7		-/-						
6		-/-						
5		-/-						
4	+2	-/-	+2	Х				
3	-2	-/-	-2	Х				
2	-1	-/-	-1	X				
1	+1	-/-	+1	х				


Contacts are made in "X" marked position.


	Symbols for interconnection: []					
Technical data	Symbol	Symbol		Unit		
nominal voltage (DC poles)	Ue		600	V dc		
nominal current (DC poles)	te		16	A dc		
nominal voltage (second rating DC poles, if requested)	Ue			V dc		
nominal current (second rating DC poles, if requested)	le			A dc		
nethod of mounting DIN rail and or Base mounting [B]						
number of DC poles			4			
utilization category DC			DC-218			
actuator	standard black	standard black [A],				
positions	OFF at 12 hr, O	OFF at 12 hr, ON at 3 hr [E]				
rated impulse withstand voltage	Uimp		8	kV		
insulation voltage	Ui		600	٧		
rated thermal current uninterrupted duty	lu		16	Α		
rated short-time withstand current (1s)	lcw		480	A		
rated short-circuit making capacity	Icm		1,4	kA		
rated conditional short-circuit current			5	kA		
max. cut-off current				kA		
max power dissipation			1,6	W		
method of operation	od of operation independent manual operation					
minimum required dimensions of enclosures I x w x h*		124	x 47 x 74	mm		
* see the drawing for the height of the switch. The number	of layers H is:		4			
terminal screws M4 need a tightening torque, min max.		1,5	1,7	Nm		
tightening torque screw in the standard black knob, min r	nax.	0,5	0,7	Nm		
minimum required fine wire cross-section: IEC60947-1, tab	le 9		2,5	mm		
ambient temperature allowed between		-5	and + 40	·c		
storage temperature allowed between		- 40	and + 80	*c		
maximum relative humidity, without condensation at 20°C			90	%		
pollution degree			2			
IP rating terminals			IP20			
IP rating gland of the shaft in case of single hole panel mou	nting					
nominal voltage (AC poles)	Ue		0	VAC		
nominal current (AC poles)	le		0	A A		
number of DC poles			0			
auxiliary contact, nominal current 16A at 250 V, AC15 No auxiliary contact						
weight			221	g		
accessories:	0					
	0					


- santon











95,1

Mounting instructions

In the application all ratings have to be respected. When building the switch in an enclosure, the space envelope must be respected. The terminals can take flexible wires up to 6 mm² and fork shoes for wires up to 10 mm² (type 3547C from Vogt). After mounting, the wiring must be checked and the switch must operate smoothly.

The X type switches are designed for a very long life but it is advised to do some simple yearly maintenance.

- Check the installation for signs of overload or overheating. The terminals may not exceed the limit of 85°C under
- By operating the switch a few times (5x) the contacts will clean themselves and the switch will have a longer life.

Dimensions, specifications and data shown could be subject to change without notice.

JD Auspice Co.,Ltd. TEL: 886-2-2595-9780 FAX: 886-2-2595-9412 service@jdauspice.com www.jdauspice.com