Switch disconnector for solar application according to IEC 60947-3 by KEMA to be certified






		- 1	Terminals	Schen	ne				
Layer No.	Front Side		Combat	Rear Side		On Positions			
	Left	Right	Symbol	Left	Right	1	2	3	4
			-/-						
			-/-						
			-/-						
			-/-						
9	-2	Г	_/_	1 -2			X		X
8		-2	_/_		-2		X		X
7	+2	-	_/_	+2			X		X
6		+2	-/-	l _e	+2		X		X
5	-1	ſ	_/_	-1			X		X
4		-1	_/_		-1		X		X
3	+1	-	-/-	+1			Х		Х
2		+1	_/_		+1		Х		Х
1			empty				Х		X

Contacts are made in "X" marked position.
Symbols for interconnection: [

Technical data	Symbol	bols for interconnection: [Merit		Unit	
rated operational voltage (DC poles)	Ue	- 000000000	00	V dc	
rated operational current (DC poles)	le		36	A dc	
rated operational voltage (second rating DC poles, if requested)	Ue		00	V dc	
rated operational current (second rating DC poles, if requested)	le		50	A dc	
method of mounting	1005	n and single hole mounting [D]	50	A de	
number of DC poles	DOLLI DOLLO	in and single note mounting [D]	4		
utilization category DC	DC-21B				
actuator	ordered wit	hout a knob			
positions	OFF at 3 hr, ON at 6 hr, OFF at 9 hr, ON at 12 hr				
rated impulse withstand voltage	Uimp	011 011 017 017 017 017 017 017 017 017	8	kV	
insulation voltage	Ui	10	00	V	
rated thermal current uninterrupted duty	lu		50	A	
rated short-time withstand current (1s)	lcw		50	A	
rated short-circuit making capacity	Icm		1,4	kA	
rated conditional short-circuit current	1400		5	kA	
max power dissipation			28	W	
method of operation	independen	t manual operation			
minimum required dimensions of enclosures L x W x H*	тасрепаст	124 x 47 x 126	5.5	mm	
* see the drawing for the height of the switch. The number of layers N is:		**********	9		
Shaft length				mm	
Enclosure depth from inside bottom to outside top, required for the switch a	and knob	159	9.5	mm	
tightening torque terminal screws M4 , min max.			1,7	Nm	
tightening torque panel mounting nut, min max.			2,5	Nm	
tightening torque M3 screw in the standard black knob, min max.			0.7	Nm	
minimum required fine wire cross-section: IEC60947-1, table 9			x6	mm2	
ambient temperature allowed between		- 20 to + 70	°C	°C	
storage temperature allowed between		- 40 to + 80	°C	°C	
maximum relative humidity, without condensation at 20°C			90	%	
pollution degree			2	-0.5	
IP rating terminals		IP	20		
IP rating gland of the shaft in case of single hole panel mounting		IP.	65		
rated operational voltage (AC poles)	Ue			V ac	
rated operational current (AC poles)	le			Aac	
number of AC poles					
auxiliary contact(s), AC15		No au	xiliar	y contac	
auxiliary contact ratings					
weight		38	34	g	
accessories:	- 1.5				
	-				
Superior Switch Solutions					



Mounting instructions


In the application all ratings have to be respected. When building the switch in an enclosure, the space envelope must be respected according to the applicable standards. The terminals, without interconnection can take copper wires up to 6 mm2. The recommended Spade Tongue Terminals may have a maximum width of 9 mm. For CSA and UL applications, registered Spade Tongue Terminals must be used. The registration numbers are UL: E13288 and CSA: LR7189 (for instance type 165015 from Tyco). After mounting, the wiring must be checked and the switch must operate smoothly.

124

Maintenance

The X type switches are designed for a very long life but it is advised to do some simple yearly maintenance.

- Check the installation for signs of overload or overheating. The terminals may not exceed the limit of 85°C under full load.
- By operating the switch a few times (5x) the contacts will clean themselves and the switch will have a longer life.



Dimensions, specifications and data shown could be subject to change without notice.

Superior Switch Solution