Data Sheet


Switch disconnector for solar application according to IEC 60947-1&3 by Dekra (KEMA)



Layer Front Side Symbol Rear Side On Positive No. Left Right 1 2 3 Image: Constraint of the symbol Image: Consymbol Image: Constraint of the symbol				Terminals	Schem	ne			
No. Left Right ' Left Right 1 2 3 -	Layer			Combal			On Positi		
6	No.	Left	Right	Symbol	Left	Right	1	2	3
6 +2 5 -2 4 -1 3 +1 2 +1 1 empty Contacts are made in "X" marked position. Symbols for interconnection: [
6 +2 4 -1 -2 3 -1 -1 2 +1 -1 1 empty +1 2 -1 -1 5 -2 -1 -1 3 -1 -1 -1 1 empty +1 -1 1 ontacts are made in "X" marked position.									
6 +2 4 -1 3 +1 2 +1 1 empty Contacts are made in "X" marked position. Symbols for interconnection: [
6 +2 5 -2 4 -1 3 +1 2 +1 1 empty Contacts are made in "X" marked position. Symbols for interconnection: [
6 +2 5 -2 4 -1 3 +1 2 +1 1 empty Contacts are made in "X" marked position. Symbols for interconnection: [
6 +2 5 -2 4 -1 3 +1 2 +1 1 empty Contacts are made in "X" marked position. Symbols for interconnection: [
6 +2 5 -2 4 -1 3 +1 2 +1 1 empty Contacts are made in "X" marked position. Symbols for interconnection: [7			_/_	12				_
5 -2 -2 -2 4 -1 -2 -1 3 -1 -1 -1 2 -1 +1 -1 1 empty +1 -1 Contacts are made in "X" marked position. Symbols for interconnection: [72	+2	_	_	-
4 -1 -1 3 -1 +1 2 +1 +1 1 empty -1 Contacts are made in "X" marked position. Symbols for interconnection: [-2			-2	+2			-
3 +1 2 +1 1 empty Contacts are made in "X" marked position. Symbols for interconnection: [-1	_/_		-1	_		
1 empty Contacts are made in "X" marked position. Symbols for interconnection: [_	-/-	+1				
Contacts are made in "X" marked position. Symbols for interconnection: [2			-/-		+1			
Symbols for interconnection: [1			empty					
		Conta	cts are	made in "?	K" mar	ked pos	sitio	n.	
			ols for i	nterconne	ction:	[


X X X X X X X

	Symbols for interconnection: [
Technical data	Symbol Merit		Unit			
rated operational voltage (DC poles)	Ue	1000	V dc			
rated operational current (DC poles)	le	32	A dc			
rated operational voltage (second rating DC poles, if requested)	Ue	0	V dc			
rated operational current (second rating DC poles, if requested)	le	0	A dc			
rated operational voltage (third rating DC poles, if requested)	Ue	0	V dc			
rated operational current (third rating DC poles, if requested)	le	0	A dc			
method of mounting	both bottom and single hole m	ounting [D]				
number of DC poles		4				
utilization category DC						
actuator	knob with padlock and top scre	w, red/grey [H]				
positions	OFF at 9 hr, ON at 12 hr [H]					
rated impulse withstand voltage	Uimp	8	kV			
insulation voltage	Ui	1000	V			
rated thermal current uninterrupted duty	lu	32	А			
rated short-time withstand current (1s)	lcw	750	А			
rated short-circuit making capacity	lcm	1,4	kA			
rated conditional short-circuit current		5	kA			
max power dissipation		4,1	W			
method of operation	independent manual operation					
minimum required dimensions of enclosures L x W x H*		124 x 47 x 105,5	mm			
* see the drawing for the height of the switch. The number of layers N is:		7				
Enclosure depth from inside bottom to outside top, required for the switch and l	knob	138,5	mm			
knob operation force	max.	1,4	Nm			
tightening torque terminal screws M4 , min max.	1,5	1,7	Nm			
tightening torque panel mounting nut, min max.	2,0	2,5	Nm			
tightening torque M3 screw in the standard black knob, min max.	0,5	0,7	Nm			
minimum required fine wire cross-section: IEC60947-1, table 9	· · · · · · · · · · · · · · · · · · ·	6	mm2			
ambient temperature allowed between		- 20 to + 70	°C			
storage temperature allowed between		- 40 to + 80	°C			
maximum relative humidity, without condensation at 20°C		90	%			
pollution degree		2				
IP rating terminals		IP20				
IP rating gland of the shaft in case of single hole panel mounting		IP65				
rated operational voltage (AC poles)	Ue		V ac			
rated operational current (AC poles)	le		A ac			
number of AC poles (for general use)						
minimum required fine wire cross-section: IEC60947-1, table 9			mm2			
auxiliary contact(s), AC15		No auxiliar	rv contact			
auxiliary contact ratings						
weight		315	g			
accessories:	-		U			
	-					
Superior Switch Solutions						





PANEL CUTOUT



Mounting instructions

In the application all ratings have to be respected. When building the switch in an enclosure, the space envelope must be res pected according to the applicable standards. The terminals, without interconnection can take copper wires up to 6 mm2. The recomme nded Spade Tongue Terminals may have a maximum width of 9 mm. For CSA and UL applications, registered Spade Tongue Terminals must be used. The registration numbers are UL: E13288 and CSA: LR7189 (for instance type 165015 from Tyco). After mounting, the wi ring must be checked and the switch must operate smoothly.

Maintenance

The X type switches are designed for a very long life but it is advised to do some simple yearly maintenance. - Check the installation for signs of overload or overheating. The terminals may not exceed the limit of 85 °C under full load.

By operating the switch a few times (5x) the contacts will clean themselves and the switch will have a longer life.

A type knob D type knob B type knob O type knob

Dimensions, specifications and data shown could be subject to change without notice.