CERTIFICATE

Issued to: Applicant: Santon International B.V. Hekendorpstraat 69 3079 DX Rotterdam, The Netherlands

Licensee: Santon International B.V. Hekendorpstraat 69

3079 DX Rotterdam, The Netherlands

Product Rotary switch-disconnector

Trade name(s) SANTON Type(s)/model(s) XBE+

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of

- a type test according to the standard EN 60947-3:2009 EN 60947-3:2009 A1:2012 and EN 60947-3:2009/A2:2015
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 901095

DEKRA hereby grants the right to use the KEMA-KEUR certification mark

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 11 April 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-103409

DEKRA Certification B.V.

drs. G.J. Zoetbrood Managing Director

Kreny Lin Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE **DUTCH ACCREDITATION** COUNCIL







SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product : Rotary switch-disconnector

Trade name(s) : SANTON
Type(s)/model(s) : XBE+
Rated insulation voltage (Ui) : 1100 V
Conventional free air thermal current : 50 A

(Ith)

Utilization category : DC-PV1

Rating (Ue-le) : Ue = 500 Vdc / Ie = 50 A

Ue = 800 Vdc / le = 25 A Ue = 1000 Vdc / le = 16 A Ue = 1100 Vdc / le= 10 A : 8 kV

Rated impulse withstand voltage

(Uimp)

Connection capacity : 1 mm² - 4 mm² flexible

6 mm² - 10 mm² with special terminal lug

Method of operation : independent operation, rotary

Applied actuator knobs : optionally provided with actuator knob

Number of position of contacts : 2 positions (0°, 90° or 0°, 270°)

Number of poles type of contact : maximum 8 poles, 1 single pole contact per pole Contact composition : min 1 contact in + pole and 1 contact in -pole

Degree of potection : IP20

IP66 when mounted in an enclosure with gland of the shaft for

panel mounting

For use in ambient temperatures : -40°C to 70°C (Ue = 500 V, 800 V, 1000 V)

-40°C to 70°C (Ue = 1100 V)

TESTS

Test requirements

EN 60947-3:2009

EN 60947-3:2009/A1:2012 EN 60947-3:2009/A2:2015

Test result

The test results are laid down in DEKRA test file 222099200.

Conclusion

The examination proved that all requirements were met.

Factory location

Santon Holland B.V. Hekendorpstraat 69 3079 DX Rotterdam, The Netherlands