# CERTIFICATE

Issued to: Applicant: Santon International B.V. Hekendorpstraat 69 3079 DX Rotterdam, The Netherlands

Licensee: Santon International B.V. Hekendorpstraat 69 3079 DX Rotterdam, The Netherlands

Product Rotary switch-disconnector

Trade name(s) SANTON Type(s)/model(s) XBE+

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of

- a type test according to the standard EN 60947-3:2009, EN 60947-3:2009/A1:2012 and EN 60947-3:2009/A2:2015
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 901095

DEKRA hereby grants the right to use the KEMA-KEUR certification mark

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 11 April 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-103409

**DEKRA Certification B.V.** 

drs. G.J. Zoetbrood Managing Director

Kreny Lin Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE **DUTCH ACCREDITATION** COUNCIL







### SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product : Rotary switch-disconnector

Trade name(s) : SANTON
Type(s)/model(s) : XBE+
Rated insulation voltage (Ui) : 1100 V
Conventional free air thermal current : 50 A

(Ith)

Utilization category : DC-PV1

Rating (Ue-le) : Ue = 500 Vdc / Ie = 50 A

Ue = 800 Vdc / le = 25 A Ue = 1000 Vdc / le = 16 A Ue = 1100 Vdc / le= 10 A : 8 kV

Rated impulse withstand voltage

(Uimp)

Connection capacity : 1 mm² - 4 mm² flexible

6 mm<sup>2</sup> - 10 mm<sup>2</sup> with special terminal lug

Method of operation : independent operation, rotary

Applied actuator knobs : optionally provided with actuator knob

Number of position of contacts : 2 positions (0°, 90° or 0°, 270°)

Number of poles type of contact : maximum 8 poles, 1 single pole contact per pole Contact composition : min 1 contact in + pole and 1 contact in -pole

Degree of potection : IP20

IP66 when mounted in an enclosure with gland of the shaft for

panel mounting

For use in ambient temperatures : -40°C to 70°C (Ue = 500 V, 800 V, 1000 V)

-40°C to 70°C (Ue = 1100 V)

## **TESTS**

# Test requirements

EN 60947-3:2009

EN 60947-3:2009/A1:2012 EN 60947-3:2009/A2:2015

### Test result

The test results are laid down in DEKRA test file 222099200.

## Conclusion

The examination proved that all requirements were met.

## **Factory location**

Santon Holland B.V. Hekendorpstraat 69 3079 DX Rotterdam, The Netherlands